

Magnetic Fields from High Voltage Power Cables

Edstan Fernandez and Jayson Patrick, Electrotechnik Pty Ltd www.elek.com.au

Abstract— This paper analyses the magnetic fields, in the context of a health and safety-related issue, produced by electrical power cables installed in various configurations under varying conditions. A specialist calculation module in-built to ELEK™ Cable High Voltage software has been used for calculating the results based on the Biot-Savart law.

Index Terms: Magnetic fields, Biot-Savart law, phase shift, ELEK™ Cable High Voltage software

I. INTRODUCTION

There are electric power cables in use all around us. The current that a cable carries generates a magnetic field that emanates in all directions. Medical research has shown that exposure to magnetic fields above safe limits can have a significant detrimental effect on health. The International Commission for the Protection against Non-Ionizing Radiation Protection has set 1 mT as the reference limit for occupational exposure and 200 μ T as the public exposure limits [1, 2].

For new or existing power projects involving electric cables, since these cables often carry high currents and are installed low to or under the ground near to where people cohabit there is often a requirement to calculate and to measure the magnetic field. ELEK™ Cable HV software has a specialised module for easily and accurately calculating the magnetic fields from cables.

This paper provides a parametric study of factors affecting the magnetic field around a cable such as soil permeability, load current magnitude and phase angle at varying measurement distances. The presented results include those for multiple circuits, installed in various industry-standard configurations such as horizontal, vertical and trefoil and for varying load currents which are balanced or unbalanced.

The assumptions of the calculations are that

- The cables are infinitely long conductors.
- The air and/or soil is assumed to be electromagnetically homogeneous, isotropic and linear.
- Eddy currents losses can be neglected because of low penetration depth for earth electrical resistivities between 10 – 100 Ω -m (assumed) at 50 / 60 Hz.

- Induced currents in the cables, neutral wires, neighbouring cables and all other structures are ignored.
- For cables in air or soil relative permeability is 1.
- Currents used are RMS values.
- The superposition principle is applied where the field produced by each cable is combined to obtain the total field.

II. MATHEMATICAL FORMULATION

A. Magnetic field of a single conductor

The Biot-Savart law explains the fundamental quantitative relationship between an electric current which is flowing and the magnetic field it produces.

The value of the magnetic field (B) at a point in space with relative permeability μ_0 is the sum of all the contributions from each small element or segment of a current-carrying conductor. For a very long straight conductor carrying current the magnetic field at a nearby point is proportional to the value of the current and inversely proportional to the perpendicular distance from the conductor to a given point (x, y) as follows

$$B = \frac{\mu_0 I}{2\pi\sqrt{x^2 + y^2}}$$

The magnetic field has two components, one along the x axis B_x and another along the y axis B_y . If θ is the angle between B and B_x then, the components can be written as

$$B_x = -B \sin\theta = \frac{-\mu_0 I y}{2\pi(x^2 + y^2)}$$

$$B_y = B \cos\theta = \frac{-\mu_0 I x}{2\pi(x^2 + y^2)}$$

$$B = \sqrt{B_x^2 + B_y^2}$$

B. Magnetic field of multiple conductors - same phase angle

The magnetic field produced by multiple conductors is calculated as the summation of the magnetic fields caused by the individual conductors. Consider n conductors carrying currents I . The positions of the conductors are (x_i, y_i) .

As derived from earlier equations the horizontal and vertical components of the magnetic field is the summation of the components of each individual conductor from a measurement point (x_k, y_k) .

$$\text{Horizontal component, } B_{xi} = \sum_{i=0}^n -\frac{\mu_r \mu_0}{2\pi} I_i \left[\frac{y_k - y_i}{r_{ik}^2} \right]$$

$$\text{Vertical component, } B_{yi} = \sum_{i=0}^n \frac{\mu_r \mu_0}{2\pi} I_i \left[\frac{x_k - x_i}{r_{ik}^2} \right]$$

where r_{ik} is the distance between the conductor and the point of measurement and is given by

$$r_{ik} = \sqrt{(x_k - x_i)^2 + (y_k - y_i)^2}$$

So, the magnetic field at any point (x_k, y_k) is

$$B = \sqrt{B_{xi}^2 + B_{yi}^2}$$

C. Magnetic field of multiple conductors - different phase angles

The current in each conductor can be resolved into the corresponding in-phase and out-phase components. Therefore, if we consider a three-phase circuit, the horizontal and vertical component of the magnetic field will have components due to in-phase and out of phase currents for each conductor.

Consider a three-phase system carrying currents with a phase difference of 120° .

$$I_A = I \angle 0, I_B = I \angle 120, I_C = I \angle -120$$

Each component of the magnetic field will have an in-phase component and an out-phase component i.e. each cable will have $B_{xin}, B_{xout}, B_{yin}$ and B_{yout} . For n cables the x and y components of fields are given by

$$B_x = \sqrt{\left\{ \sum_{i=1}^n B_{xin_i} \right\}^2 + \left\{ \sum_{i=1}^n B_{xout_i} \right\}^2}$$

$$B_y = \sqrt{\left\{ \sum_{i=1}^n B_{yin_i} \right\}^2 + \left\{ \sum_{i=1}^n B_{yout_i} \right\}^2}$$

$$B = \sqrt{B_x^2 + B_y^2}$$

D. Effects of soil permeability on magnetic field

Electric power cables are commonly buried underground, and the magnetic field needs to be calculated above the ground surface level. In this case the magnetic field depends on the relative permeability of the two adjacent mediums being the air and the soil. To calculate the magnetic field in the air caused by a current flowing in a buried conductor(s) the image method is used which considers soil permeability.

An image current in the same direction appears if a current is placed parallel to a plane surface of differing permeability. The vector potential in the other region can be calculated by summing the contributions from the original current and the image current. This image current is perpendicular to the surface. So, the image current is

$$I' = \frac{\mu_{r_m} - \mu_{r_a}}{\mu_{r_m} + \mu_{r_a}} I$$

The new current is

$$I_{new} = I' + I = \frac{\mu_{r_m} - \mu_{r_a}}{\mu_{r_m} + \mu_{r_a}} I + I = \frac{2\mu_{r_m}}{\mu_{r_m} + \mu_{r_a}} I$$

where μ_{r_m} is the relative permeability of soil and μ_{r_a} is the relative permeability of air. If $\mu_{r_m} = 1$ the effect of soil can be neglected and $I_{new} = I$.

In fact, it has been shown that the relative permeability of soil varies so slightly from that of air that the effect on magnetic field can be ignored (see the simulation results herein).

III. SIMULATION RESULTS

The simulations are carried out for single and multiple circuits of single core high voltage cables arranged in different buried configurations. The current ratings were calculated using the ELEK™ Cable High Voltage software.

A. Magnetic field as a function of soil permeability and current magnitude

The magnetic field produced by a current-carrying buried cable is directly proportional to the soil permeability. Various types of soil and their magnetic permeabilities are discussed in [3] and are shown to not vary by a lot.

A simulation was performed with 530 A current for a standard three phase circuit with the cables touching and buried 1 m below the ground. Measurements of magnetic field were taken at ground level. Figure 2 shows that the minimum

magnetic field (6.9498 μT) was obtained at $\mu_{rm} = 1$ and as soil permeability increases so too does the magnetic field increase.




Fig. 2: Magnetic field densities for varying soil permeabilities for a single circuit horizontally laid UG cable.

Another simulation was carried out for multiple (2) circuits. Both three phase, single core cable circuits were laid horizontally. The circuit on the right-hand side carried a much lower current than that on the left. The separation between the circuits was 2 m.

Figure 3 confirms that the magnetic field is stronger for higher currents. This is shown by the maximum magnetic field at all soil permeabilities occurring at the centre of the cable carrying the largest current on the left.




Fig. 3: Magnetic field for varying soil permeabilities for a multiple circuit horizontally laid UG cable.

B. Magnetic field as a function of phase sequence

Phase sequence and the relative positions between laid cables relates to an interesting practical problem. The magnetic fields from adjacent cables interact with one another according to the equations presented earlier in this paper. The way or the degree in which they interact must be balanced to ensure the currents are balanced (equal) between phases. Unbalanced loading of cables within circuits is undesirable and could result in overheating. There are recommended phase arrangements / configurations given by industry standards which aim at avoiding or at least minimising phase current unbalance.

For example, one industry-standard recommends the following physical phase arrangement for two three-phase circuits.




Figure 4 shows the variation of magnetic field with the change in phase sequence for two three phase circuits arranged as above. The current carried by the conductors are 465A. The minimum magnetic field of obtained is 5.398 μT when the phase of the first circuit is [0 -120 120] and that of the second circuit is [120 -120 0] i.e. ABC - CBA. This confirms what the industry-standard has recommended. It is simple to verify the various other recommended configurations by plotting the resultant magnetic field.




Fig. 4: Magnetic field for 2 conductor/phase horizontal configuration

C. Magnetic field and distance of measurement

Magnetic field is calculated and measured at a relevant height to establish what the values of exposure might affect people (typically 1 m above ground level).

Since the magnetic field is inversely proportional to the distance of measurement then as the distance from the cable increases the magnetic field decreases. Fig. 5 shows the variation of magnetic field with distance from a horizontally laid cable carrying 465 A. The minimum magnetic field obtained is 1.739 μT when the measurement is carried out 1 m above the ground.




Fig. 5: Magnetic field for a horizontal cable configuration

IV. CONCLUSION

Power cables emit magnetic fields which can present a health and safety problem. Even when the resultant magnetic field from a group of cables is not evenly distributed then this can cause unbalances of currents in the cables which is undesirable. It is pertinent to calculate the magnetic fields produced by cables or groups of cable circuits during the design phase to avoid any issues and allow the making of any necessary changes to their configurations.

To understand how to make the necessary changes one must understand how magnetic field varies with factors including current (generally non-changeable), spacing between cables, depth of burial, phase sequence, soil permeability (varies by little) and point of measurement. As soil permeability increases the magnetic field also increases irrespective of the configuration of the circuit but by very little for standard soils. The same is the case for multiple circuits. As the distance of measurement from the cable increases the magnetic field decreases. For buried cables the maximum magnetic field occurs at ground level and the field decays as the distance is increased. The effect of phase sequence on the magnetic field is also quite prominent. A configuration of cables of different phases which produces the highest overall magnetic field (compared with other relative configurations) will result in a worst-case phase current unbalance.

REFERENCES

[1]	International Commission on Non-Ionizing Radiation Protection (ICNIRP)- Guidelines for limiting exposure to time-varying electric and magnetic fields (1Hz – 100 kHz) published in: Health Physics 99(6):818-836: 2010; Available at https://www.icnirp.org/cms/upload/publications/ICNIRPLFgdl.pdf
[2]	International Commission on Non-Ionizing Radiation Protection (ICNIRP) Fact Sheet; Available at https://www.icnirp.org/cms/upload/publications/ICNIRPFactSheetLF.pdf
[3]	Scott, J. H. (1983). Electrical and magnetic properties of rock and soil (No. 83-915). US Geological Survey.
[4]	Patitz, W. E., Brock, B. C., & Powell, E. G. (1995). Measurement of dielectric and magnetic properties of soil (No. SAND--95-2419). Sandia National Labs.

V. APPENDIX

Soil permittivity values from [3].

Rock or soil type	Relative magnetic permeability (μ_r/μ_0)		Source of information
	Typical value	Range	
Soil and sedimentary rock (general)	1.0006	1.00001 to 1.001	Nettleton (1940)
Alluvium (NTS, Nevada)	1.004	1.0005 to 1.014	Monk (1965) (oral commun.)
Sandstone with unusually high magnetite content (Neroly Fm., California)	1.010	1.002 to 1.025	Bath (1965) (oral commun.)
Volcanic rock and soil (Amchitka Island, Alaska)	1.021	1.0001 to 1.053	Scott and Cunningham (1965) (written commun.)
Granite (Cheyenne Mtn., Colo.)	1.076	1.017 to 1.136	Scott (1965) (written commun.)
Rock in iron-mining areas (Sweden)	1.1	1.00001 to 1.4	Werner (1945)